



SE 4910 Dual Channels Isolated Signal Converter
 RS-485 COMMUNICATION INSTRUCTION MANUAL
 MODBUS Protocol Reference Guide

Modbus Register Address

Address	Word	Item (description)	Code	Unit	Sign	Range (十進制)
0000H	2	Watt Hour	03H	WH	Unsign	0~99999999
0002H	1	Watt	03H	W	Unsign	0~9999
0003H	1	Voltage	03H	V	Unsign	0~9999
0004H	1	Current	03H	A	Unsign	0~9999
0005H	1	dep 1	03H		Unsign	1: 0.000 2: 00.00 3: 000.0 4: 0000
0006H	1	dep 2	03H		Unsign	1: 0.000 2: 00.00 3: 000.0 4: 0000
0010H	1	Energy Reset	06H		-----	1234 Hex : Reset Σ Watt hour

Ex : 讀取資料

Send : 01 03 00 00 00 02 CRC

Received : 01 03 04 XX XX XX XX CRC